

DESIGN OF ENERGY STORAGE UNIT FOR THE SPARTAN SUPERWAY TRANSPORTATION NETWORK

ME295A
May 14, 2020


Committee: Dr. Burford Furman, Mr. James Mokri, and Mr. Ron Swenson

By: Carlos Franco

PERSONAL BACKGROUND



SJSU SAN JOSÉ STATE
UNIVERSITY



THIS PRESENTATION FOCUSES ON CURRENT RESEARCH AND ANALYSIS FOR STORAGE UNIT DESIGN OPTIONS




Introduction / Background



Methodology




Objectives




Results / Summary


THE SPARTAN SUPERWAY IS AN OPPORTUNITY REDUCE INIMICAL IMPACTS OF MODERN TRANSPORTATION METHODS



PROPOSE DESIGN FOR ENERGY STORAGE UNIT THAT CAN BE
DEPLOYED FOR SUPERWAY NETWORK



TRANSPORTATION SECTOR HAS CRITICAL IMPLICATIONS ON THE ENVIRONMENT AND PUBLIC SAFETY




Share of U.S. GHG Emissions by Sector, 2017^{3,4}

Note: Totals may not add to 100% due to rounding.

Share of U.S. Transportation Sector GHG Emissions by Source, 2017^{4,5}

Note: Totals may not add to 100% due to rounding.



THE SPARTAN SUPERWAY IS CONSIDERED AN AUTOMATIC TRANSIT NETWORK



PRT Morgantown, West Virginia



ParkShuttle, Netherlands



PRT, Madagascar




Shuttle, London





PRT, South Korea

MEGAWATT AND GIGAWATT ARRAYS ARE BECOMING MORE COMMON WHILE SYSTEMS SHOW DECREASING COSTS


PV Cell Technology	Band-gap [eV]	Manufacturing Processes	Efficiency Record [%]
Crystalline Silicon			
Mono-crystalline	1.11	Cz-Si, float-zone, BST	27.6 (26.1) ^a
Poly-crystalline	1.11	BCG, block-casting	22.3
HIT	1.11	Deposition	26.6
Micro	1.11	PECVD, HWCVD	21.2
Thin-film			
CIGS	1.7	scr.-print, coat, MOCVD	23.3 (22.9) ^a
CdTe	1.5	sputter., HVE, MOCVD	22.1
Amorphous Si:H	1.5–1.8	PECVD	14
GaAs	1.42	VGF, BST, LEC, MOCVD	30.5 (29.1) ^a
Multi-junction	multiple	MOCVD, mech.-stacking	46
Emerging			
Organic	1–4	Roll-to-roll mfg.	15.6
Dye-sensitized	≈ 3.2	Roll-printing	11.9
Perovskite	≈ 1.5	spin-coat, scr.-print, VD	28 (24.2) ^a




LITHIUM TECHNOLOGIES SHOW POTENTIAL FOR STORAGE SYSTEMS WHILE SYSTEMS SHOW DECREASING COSTS



UTILITY-SCALE SYSTEMS ARE USING LITHIUM BATTERIES



THE GRID AND STORAGE SYSTEMS CAN WORK TOGETHER BY FOLLOWING STANDARDS



Standard No.	Title of Standard	Publication
IEC 61727-2004	PV systems—characteristics of the utility interface	International Electrotechnical Commission
IEEE Std 1547TM-2003 (R2008) (including amendment IEEE 1547a-2014)	IEEE Standard for interconnecting DRs with electric power systems	The Institute of Electrical and Electronics Engineers
IEEE Std 929-2000	Recommended practice for utility interface of PV systems	The Institute of Electrical and Electronics Engineers
Rule 21-2014	Generating facility interconnections	California of America

TRANSIT ENERGY EQUATION AND COMPUTER MODEL TO DETERMINE ENERGY DEMAND OF SYSTEM

$$t_s = t_D + \frac{D_s}{V_L} + \frac{V_L}{a_m} + 1$$

$$E(t_s) = \frac{1}{\bar{\eta}_m} \left\{ (1 - \eta_{regen}) N_T \frac{m_v V_L^2}{2} + \frac{1}{2} \rho_{air} C_D A_v \left[(V_L^2 + \langle V_w^2 \rangle) D_s - \frac{V_L^4}{2a_m} \right] + N_T m_v \left[k_{srr} \frac{C_{srr} g D_s}{R_w} + C_{drr} V_L \left(D_s - \frac{V_L^2}{3a_m} \right) + \Delta h_{avg} g \right] \right\} + N_T P_{aux} t_s$$

Vehicle Hourly Demand

$$E_{vhd} = \frac{E_{ahd}}{N_v}$$

Vehicle Number

$$N_{vn} = \frac{N_{sp}}{N_p}$$

Hourly System Demand

$$E_{hsd} = N_{vn} E_{vhd}$$

HOURLY ARRAY POWER OUTPUT EQUATION AND COMPUTER MODEL TO DETERMINE PV ENERGY SUPPLY

$$P_{A,h} = \eta_{elec} \sum_{N_{sub}} (P_{mod,un,h} N_{un,h} + P_{mod,sh,h} N_{sh,h})$$

$$\eta_{elec} = \eta_{inv} \eta_{wire} \eta_{con} \eta_{mis}$$

System Hourly
Power Output

$$\rightarrow P_{sys,h} = \sum_{N_A} P_{A,h}$$

BATTERY SIZING CALCULATIONS ACCOUNTING FOR INEFFICIENCIES AND SAFETY FACTOR






$$E_{td} = \Sigma E_{hsd}$$

$$E_{ts} = \Sigma P_{sys,h}$$

$$E_{tea} = E_{ts} - E_{td}$$



$$L_B = \frac{E_{tea}}{\eta_{inv} n_{wir}} \longrightarrow \text{X 1.25 Factor}$$

SEARCHING FOR DESIGN AND LAYOUT OPTIONS



APPROXIMATING PROJECTED COST TRENDS FOR THE STORAGE CAPACITY NEEDED

$$\text{Total Cost} \left(\frac{\$}{\text{kWh}} \right) = \text{Energy Cost} \left(\frac{\$}{\text{kWh}} \right) + \text{Power Cost} \left(\frac{\$}{\text{kW}} \right) / \text{Duration (hr)}$$




VEHICLE HOURLY DEMAND WAS CALCULATED TO 10.4 KWH

System and Route Characteristics	
Vehicle Mass (kg)	1900
Vehicle Frontal Area (m ²)	4
Wheel Radius (m)	0.1524
Static Rolling Resistance Coefficient (m)	0.057
Drag Coefficient	0.51
Average Electric Motor Efficiency	0.85
Regenerative Braking Efficiency	0.3
Auxiliary Power Demand (W)	3500
Line Speed (m/s)	13.4
Headway (s)	5
Dwell Time (s)	20
Average Elevation Change (m)	0
Number of Vehicles	155
Number of Stations	14
Route Length (km)	14.9
Average Station Distance	1.49
Average Trip Duration	2.29


Yearly Demand
14.1 GWh

Average Vehicle Efficiency
.27 kWh / km

SYSTEM POWER SUPPLY WAS 7.3 MW FOR LOWEST GENERATING DAY OF THE YEAR




STORAGE SIZE NEEDED TO OPERATE SYSTEM ON STORED
ENERGY CALCULATED TO 4.97 MWH (ONE DAY) / 9.95 MWH
(TWO DAYS)







		Time (hour)	Passengers	Vehicles Needed	Energy Demand (kWh)
February 11, 2019 (Least Busy)	1	12:00 am - 1:00 am	0	0	0
	2	1:00 am - 2:00 am	0	0	0
	3	2:00 am - 3:00 am	0	0	0
	4	3:00 am - 4:00 am	0	0	0
	5	4:00 am - 5:00 am	0	0	0
	6	5:00 am - 6:00 am	0	0	0
	7	6:00 am - 7:00 am	4	1	10.40
	8	7:00 am - 8:00 am	16	3	31.20
	9	8:00 am - 9:00 am	169	29	301.64
	10	9:00 am - 10:00 am	56	10	104.01
	11	10:00 am - 11:00 am	147	25	260.04
	12	11:00 am - 12:00 pm	144	24	249.63
	13	12:00 pm - 1:00 pm	89	15	156.02
	14	1:00 pm - 2:00 pm	132	22	228.83
	15	2:00 pm - 3:00 pm	132	22	228.83
	16	3:00 pm - 4:00 pm	47	8	83.21
	17	4:00 pm - 5:00 pm	101	17	176.82
	18	5:00 pm - 6:00 pm	92	16	166.42
	19	6:00 pm - 7:00 pm	55	10	104.01
	20	7:00 pm - 8:00 pm	49	9	93.61
	21	8:00 pm - 9:00 pm	28	5	52.01
	22	9:00 pm - 10:00 pm	25	5	52.01
	23	10:00 pm - 11:00 pm	8	2	20.80
	24	11:00 pm - 12:00 am	0	0	0


		Time (hour)	Passengers	Vehicles Needed	Energy Demand (kWh)
February 8, 2019 (Most Busy)	1	12:00 am - 1:00 am	0	0	0
	2	1:00 am - 2:00 am	0	0	0
	3	2:00 am - 3:00 am	0	0	0
	4	3:00 am - 4:00 am	0	0	0
	5	4:00 am - 5:00 am	0	0	0
	6	5:00 am - 6:00 am	0	0	0
	7	6:00 am - 7:00 am	15	3	31.20
	8	7:00 am - 8:00 am	50	9	93.61
	9	8:00 am - 9:00 am	142	24	249.63
	10	9:00 am - 10:00 am	134	23	239.23
	11	10:00 am - 11:00 am	232	39	405.66
	12	11:00 am - 12:00 pm	272	46	478.47
	13	12:00 pm - 1:00 pm	208	35	364.05
	14	1:00 pm - 2:00 pm	229	39	405.66
	15	2:00 pm - 3:00 pm	160	27	280.84
	16	3:00 pm - 4:00 pm	147	25	260.04
	17	4:00 pm - 5:00 pm	146	25	260.04
	18	5:00 pm - 6:00 pm	76	13	135.22
	19	6:00 pm - 7:00 pm	104	18	187.23
	20	7:00 pm - 8:00 pm	55	10	104.01
	21	8:00 pm - 9:00 pm	37	7	72.81
	22	9:00 pm - 10:00 pm	43	8	83.21
	23	10:00 pm - 11:00 pm	7	2	20.80
	24	11:00 pm - 12:00 am	0	0	0





DIVERSE DESIGN OPTIONS AVAILABLE COMMERCIALLY FOR THE SYSTEM


Specifications		Tesla Megapack	Oilfield Instrumentation Model 20-2
			
Storage Capacity	3 MWh	N/A	N/A
Dimensions	23 ft 5 in x 5 ft 3 in x ~ 8 ft	20 ft x 8 ft x ~ 8 ft	20 ft x 8 ft x ~ 8 ft
Components / Features	Battery modules, bi-directional inverters, thermal management system, AC main breaker, Controls	Combustion resistant materials, thermostat, HVAC controls, humidity indicator, audible and visual strobe warnings, and electric panels	Combustion resistant materials, thermostat, HVAC controls, humidity indicator, audible and visual strobe warnings, and electric panels
Assembly Required	No	Yes	Yes
Applications	Renewable smoothing, T&D investment deferral, voltage support, capacity support, microgrid, market participation, and frequency regulation	Lithium battery storage and related	Lithium battery storage and related
Support	Team helps to identify custom site requirements and design a solution for application	Can contact for custom project options	Can contact for custom project options
Weight	N/A	13,800 lbs	13,800 lbs
Full Distribution	0.24	N/A	N/A
Partial Distribution	1	N/A	N/A
Specifications		Tesla Powerpack	Tesla Powerwall
			
Storage Capacity	232 kWh	13.5 kWh	13.5 kWh
Dimensions	41.1 in x 54.9 in x 86.2 in (inverter - 41.1 in x 54.9 in. x 86.2 in)	45.3 in x 29.6 in x 5.75 in	45.3 in x 29.6 in x 5.75 in
Components / Features	16 battery pods, DC-DC converter, cell monitoring sensors, thermal control system (liquid cooling)	Connection point, liquid cooling, inverter, battery pack	Connection point, liquid cooling, inverter, battery pack
Assembly Required	No	No	No
Applications	Outdoor rated, peak shaving, emergency backup, load shifting, demand response, microgrid, power production, grid reliability	Weatherproof, solar self-consumption, back-up power, time-based control, off-grid capabilities	Weatherproof, solar self-consumption, back-up power, time-based control, off-grid capabilities
Support	Company support, certifications	Company support, 10 year warranty, certifications	Company support, 10 year warranty, certifications
Weight	4,847 lbs (inverter - 2,470 lbs)	251.3 lbs	251.3 lbs
Full Distribution	4	53	53
Partial Distribution	11	185	185

FOUR POSSIBLE LOCATIONS AVAILABLE FOR UNITS NEXT TO STATIONS





PROJECTED COST OF ENERGY STORAGE SYSTEM IS EXPECTED TO DECREASE IN THE UPCOMING YEARS



THERE ARE SOLUTIONS OUT THERE

